

# Energy performance certificate (EPC)

67 Sylvan Road WELLINGTON TA21 8EW	Energy rating	Valid until: <b>1 May 2034</b>
	<b>D</b>	Certificate number: <b>2811-1981-1581-6216-5593</b>

Property type	Mid-terrace house
Total floor area	74 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

## Energy rating and score

This property's energy rating is D. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

Score	Energy rating	Current	Potential
92+	<b>A</b>		
81-91	<b>B</b>		87 <b>B</b>
69-80	<b>C</b>		
55-68	<b>D</b>	62 <b>D</b>	
39-54	<b>E</b>		
21-38	<b>F</b>		
1-20	<b>G</b>		

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Wall	System built, as built, no insulation (assumed)	Very poor
Roof	Pitched, 150 mm loft insulation	Good
Window	Fully double glazed	Good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system, no cylinder thermostat	Poor
Lighting	Low energy lighting in 82% of fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

### Primary energy use

The primary energy use for this property per year is 272 kilowatt hours per square metre (kWh/m<sup>2</sup>).

## How this affects your energy bills

An average household would need to spend **£1,431 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £582 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

### Heating this property

Estimated energy needed in this property is:

- 5,723 kWh per year for heating
- 3,250 kWh per year for hot water

## Impact on the environment

This property's environmental impact rating is D. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year.

## Carbon emissions

An average household produces 6 tonnes of CO<sub>2</sub>

This property produces 3.6 tonnes of CO<sub>2</sub>

This property's potential production 0.9 tonnes of CO<sub>2</sub>

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

## Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Cavity wall insulation	£500 - £1,500	£58
2. Floor insulation (solid floor)	£4,000 - £6,000	£42
3. Hot water cylinder thermostat	£200 - £400	£56
4. Heating controls (room thermostat)	£350 - £450	£90
5. Condensing boiler	£2,200 - £3,000	£260
6. Solar water heating	£4,000 - £6,000	£78
7. Solar photovoltaic panels	£3,500 - £5,500	£587

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## More ways to save energy

Find ways to save energy in your home by visiting [www.gov.uk/improve-energy-efficiency](https://www.gov.uk/improve-energy-efficiency)

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Layla Girone-Maddocks
Telephone	07756274642
Email	<a href="mailto:epc@gibbinsrichards.co.uk">epc@gibbinsrichards.co.uk</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	ECMK
Assessor's ID	ECMK303734
Telephone	0333 123 1418
Email	<a href="mailto:info@ecmk.co.uk">info@ecmk.co.uk</a>

### About this assessment

Assessor's declaration	Employed by the professional dealing with the property transaction
Date of assessment	2 May 2024
Date of certificate	2 May 2024
Type of assessment	<a href="#">RdSAP</a>